

P.S.C. No. 7 Electricity
PENNSYLVANIA ELECTRIC COMPANY
Initial Effective Date: 10/06/2019

Leaf: 44
Revision: 0
Superseding Revision:

Rule 10 - Wiring, Apparatus and Inspection (continued)

sole expense such corrective equipment as may be directed by the Company. The Company shall not serve or continue to serve Customer loads where, in the Company's sole judgment, such loads have or may have voltage and phase characteristics that result (or may result) in intolerable harmonic distortions.

Each Applicant/Customer shall provide to the Company such service information described in Rule 4 of this Tariff. The Applicant/Customer shall be responsible and liable to the Company for any damages resulting from the Customer's failure to provide such service information.

The Company shall have the right to require Customers to provide, at their sole expense, Power Factor corrective equipment which shall maintain their average Power Factor at no less than eighty-five percent (85%) lagging. Unless corrective equipment is installed, the Company is under no obligation to serve or to continue to serve such Customers.

11. Metering

Company Obligations

The Company maintains, installs and operates a variety of meters, including Advanced Meters, and related equipment designed to measure and record Customers' consumption and usage of all electric services provided under this Tariff. The Company may, in its sole and exclusive discretion, install such meters and related equipment (including, but not limited to, telemetering equipment, and Advanced Meters) it deems reasonable and appropriate to provide electric service to Customers under this Tariff. The Company may, in its sole and exclusive discretion, install such special metering equipment as may be requested by a Customer subject to the Customer paying all of the Company's incremental material, labor, overheads and administrative and general expenses relating to such facilities. Where additional metering services and the associated costs for the additional metering services are contained within this Tariff, those costs shall be applicable and in compliance with prevailing Commission regulations.

The Company shall conduct inspections and tests of its meters in accordance with prudent electric practices and as otherwise prescribed by all applicable and prevailing Commission Rules and Regulations in 16 NYCRR § 92.