

P.S.C. No. 1 – Water
SUEZ Water New York Inc.
Initial Effective Date: April 3, 2019

Leaf No. 28
Revision: 2
Superseding Revision: 1

GENERAL INFORMATION

C. Except as to the liability, if any, imposed by law in case of loss or damage resulting from gross negligence or willful misconduct on the part of the Company, its agents or employees, the Company shall not in any way or under any circumstances be held liable or responsible to any party for any losses or damage resulting from fire or water or other causes which may occur due to the installation or presence of a private fire service connection or any pipe or fixture connected therewith; or for any losses or damage resulting from any leakage or other flow of water from said private fire service connection or any of the pipes or fixtures connected therewith; or for any losses or damage resulting from any excess or deficiency in pressure or supply of water due to any cause whatsoever.

D. All application for private fire service connections shall be made in writing on application forms provided by the Company.

E. The size of the private fire service connection shall be determined by the Customer and approved by the Company, and in no case shall exceed ten (10) inches.

F. The entire private fire service system shall be subject to the inspection, test and approval of the Company before the service is made effective. The Company shall have the right to enter the premises at any reasonable time for the purpose of making an inspection of the entire private fire service system. Any irregularities disclosed shall be cause for discontinuing service unless corrected by the Customer within ten days after written notice is given by the Company.

G. No water shall be taken or used through a private fire service connection for any purpose other than for extinguishing accidental fires, except for the purpose of testing fire fighting equipment, or as specified under paragraph (d). Such tests as mentioned above may be made only under special permit from the Company and the Company may require that its representative be present at such test.

5.7 Private Fire Hydrants

Private unmetered fire protection shall be available only through hydrants owned by the Company, adjacent to mains of the Company installed within easements granted to and accepted by the Company within private streets or in other privately owned areas. Such private fire protection shall be subject to the provisions of the preceding paragraph and to the same usage restrictions as are listed for public fire hydrants in Section 6.1. Charges are made in accordance with Service Classification No. 3.