

PSC NO: 9 GAS

LEAF: 38

COMPANY: CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

REVISION: 3

INITIAL EFFECTIVE DATE: 02/01/2020

SUPERSEDING REVISION: 1

Issued in Compliance with Order in Case 19-G-0066 dated January 16, 2020

GENERAL INFORMATION - Continued**III. General Rules, Regulations, Terms and Conditions under Which Gas Service Will Be Supplied, Applicable to and Made a Part of All Agreements for Gas Service - Continued****3. Installation of Mains and Services - Continued****(G) Service Lines and Metering - Continued**

- (2) If a meter is located outside the building;
 - (a) the service line will be deemed to terminate at the outlet of the meter, if the piping continues into the structure above ground, and
 - (b) at the outside of the building foundation wall, if the piping returns underground before entering the structure.

(H) Emergency Electric Generators:

When a Customer requests gas service for the purpose of supplying an emergency electric generator for use only during an interruption of electricity service, and for testing purposes, the following conditions shall apply:

- (1) Only sufficient emergency electric generating capacity shall be installed to provide the minimum needs for safety and health; and
- (2) The Customer shall pay all costs associated with the installation including, if necessary, all costs for system reinforcement, mains and service lines.

In addition, commencing February 1, 2020, a Residential Customer with a maximum of four dwelling units and is located in an area that is subject to a moratorium on new gas connections, who desires to install a service line solely for the purpose of supplying an emergency generator, will be allowed to do so under the the following additional conditions:

- (a) The Customer agrees to be served as an Interruptible Customer and must be able to shut down the emergency generator upon request from the Company. (The Customer will not be required to submit an annual affidavit and will not be required to have a back-up energy source as is required under interruptible service);
- (b) An AMI meter must be installed, and the Customer may not elect to opt out of this metering technology;
- (c) The Customer will be served by a service line sized to supply the load for the emergency generator exclusively; and
- (d) Any gas usage through this service line for any other purpose will result in the termination of service on that line.

(General Information - Continued on Leaf No. 38.1)**Issued By: Robert Hoglund, Senior Vice President & Chief Financial Officer, 4 Irving Place, New York, N. Y. 10003**