Status: CANCELLED Received: 05/21/2021 Effective Date: 06/01/2021

PSC No: 120 - Electricity

New York State Electric & Gas Corporation

Initial Effective Date: June 1, 2021

Leaf No. 283

Revision: 4

Superseding Revision: 3

Issued in compliance with Order in Case 19-E-0079, dated May 14, 2021.

SERVICE CLASSIFICATION NO. 11 (Continued)

Electrically Isolated Loads: (Cont'd.)

c) if the Company discovers, through billing data and/or the inspection of the customer's OSG facilities, that any of the electrically isolated OSG facilities have been reconnected to NYSEG's system, the Company will backbill the customer. A contract demand will be established by the Company and the backbill will consist of NYSEG's standby service rates, applied back to the time of OSG interconnection to NYSEG's system, and include the surcharge as set forth below in the Unauthorized OSG Interconnection by Customer section, with Late Payment Charges as applicable, set forth in the Terms of Payment section of this Service Classification.

A facility shall be considered "electrically isolated" if: (a) the electrical points of contact where interconnection with the Company could occur are separated and at least 100 feet from any other interconnected electrical service utilized by such customer, or (b) the isolated service is not within the same building or structure as any other interconnected electrical service of the customer and not housed within a common enclosure with other interconnected breakers and/or fuses of the customer. At its discretion, the Company may consider a separation of less than 100 feet between a customer's facilities and the Company's system to be electrically isolated if there are site-specific configuration circumstances warranting such a determination.

Compliance:

A customer taking standby service shall comply with all federal, state and local laws, regulations, and requirements, including the requirements listed below in the Interconnection Requirements paragraphs 1 through 8.

STANDBY SERVICE NOT APPLICABLE TO:

1. A customer that has been participating in Net Energy Metering, as identified in in PSL Section 66-j or PSL Section 66-l and pursuant to General Information Rules 22, 23, 24, 26, 27, 29, and 30, can opt into Standby Service. Such customer shall be deemed a Designated Technology Customer.

ISSUED BY: Joseph J. Syta, Vice President, Controller and Treasurer, Binghamton, New York