

P.S.C. NO. 3 ELECTRICITY
ORANGE AND ROCKLAND UTILITIES, INC.
 INITIAL EFFECTIVE DATE: February 28, 2021

LEAF: 251
 REVISION: 9
 SUPERSEDING REVISION: 8

GENERAL INFORMATION

24. STANDBY SERVICE AND STANDBY SERVICE RATES (Continued)

24.2 INTERCONNECTION REQUIREMENTS

The customer's generating plant and the Company's system may be operated in parallel or isolated operation by means of a double-throw switch as required subject to the customer's compliance with the design requirements and operating rules and procedures discussed below.

The following provisions apply to generators operated in parallel with the Company's distribution system:

- (1) The following provisions are applicable to customers with private generation facilities on their premises that (i) commenced operation between February 1, 2000 and December 30, 2004, have a total nameplate rating of 300 kVA or less, and are connected in parallel with a radial distribution feeder; (ii) commenced operation between December 31, 2004 and April 28, 2016, have a total nameplate rating of 2 MW or less, and are connected in parallel with the distribution system; or (iii) commenced operation after April 28, 2016, have a total nameplate rating of 5 MW or less, and are connected in parallel with the distribution system:
 - (a) Customers' applications for service under this General Information Section for generation facilities with a total nameplate rating of 5 MW or less and applications for single phase generating equipment with a total nameplate rating of 15 kW or less shall be made using the applicable application form set forth in the Addendum – SIR to this Rate Schedule.
 - (b) The conditions under which generating equipment shall be interconnected and operated in parallel with the Company's system are set forth in the Addendum - SIR. Assuming the conditions of the Addendum - SIR are met, the Company and the customer shall execute the New York State Standardized Contract set forth in the Addendum – SIR.

Issued By: Robert Sanchez, President, Pearl River, New York

Suspended to 06/27/2021 by order in Case 21-E-0074. See Supplement No. 45. The supplement filing date was 02/26/2021.
 Suspended to 06/27/2021 by order in Case 21-E-0074. See Supplement No. 45. The supplement filing date was 02/26/2021.
 Suspended to 12/27/2021 by order in Case 21-E-0074. See Supplement No. 47. The supplement filing date was 06/08/2021.
 Suspended to 05/26/2022 by order in Case 21-E-0074. See Supplement No. 49. The supplement filing date was 12/01/2021.
 Cancelled by supplement No. 50 effective 04/21/2022