

PSC NO: 10 – Electricity  
Consolidated Edison Company of New York, Inc.  
Initial Effective Date: 12/01/2017

Leaf: 461  
Revision: 2  
Superseding Revision: 1

## **SERVICE CLASSIFICATION NO. 11 BUY-BACK SERVICE**

### **Applicable to Use of Service for**

The purchase of capacity and energy by the Company from a Qualifying Facility ("Customer"), as defined in Special Provision (A), subject to the Common Provisions and Special Provisions of this Service Classification.

The Company reserves the right to limit the amount of capacity and energy it will take from the Customer or to refuse to accept a Customer under this Service Classification where engineering considerations dictate that such actions are reasonable. Export of power on the secondary network will be permitted only for inverter-based Electric Energy Storage systems.

### **Character of Service**

Of the various characteristics of service listed and more fully described in General Rule 4, the following may be designated for service by the Company under this Service Classification, subject to the limitations set forth in such rule and in this Service Classification. Frequencies and voltages shown are approximate. All are continuous.

#### **Standard Service**

Any derivative of the standard alternating current, 3 phase, 4 wire system at 60 cycles and 120/208 volts.

#### **Non-Standard Service**

Low Tension Alternating Current - 60 cycles:

- Single phase at 120/240 volts
- Three phase at 240 volts
- Two phase at 120/240 or 230 or 240 volts
- Three phase at 265/460 volts

High Tension Alternating Current - 60 cycles:

- Three phase at 2,400/4,150 volts
- Three phase at 13,200 volts
- Three phase at 26,400 volts
- Three phase at 33,000 volts

Transmission Alternating Current - 60 cycles:

- Three phase at voltages above 33,000 volts

Issued by: Robert Hoglund, Senior Vice President & Chief Financial Officer, New York, NY