PSC NO: 2 ELECTRICITY COMPANY: MOHAWK MUNICIPAL COMMISSION INITIAL EFFECTIVE DATE: 6/01/2018

LEAF: 6 REVISION: 4 SUPERSEDING REVISION: 0

SERVICE CLASSIFICATION NO. 1 (CONT'D)

- D. If the customer proposes to install computers, solid state devices, or other voltage sensitive equipment, the Customer may have to safeguard this equipment by the application of line filters, solid state line-voltage regulators, transient suppressors, isolating transformers, uninterruptible power supply (UPS) systems or motor generators. Utility distribution systems normally operate between certain voltage limits as established by National Standards. The Utility should be contacted for further guidance.
- E. Multiple meters at single-family dwellings or at individual flats or apartments in multiple-family dwelling shall be combined into a single billing for said single-family dwellings, or for individual flat or apartment in multiple-family dwellings.
- F. The character of service (voltages) for service to apartmental units shall be 120/240 volt or single phase or 120/208 volt, three phase, four wire, Wye at the Utility's option based on availability, loadings, etc. All meters shall be furnished and installed by the Utility. For installations in excess of six (6) metered positions, the Customer shall install the meter module within the structure and shall be accessible to Utility personnel on a round-the-clock basis. Location of meter modules will not be accepted if location is to be utilized as any form of storage facility. Total access to the meter module must be guaranteed by the Customer.
- G. The Customer shall apply for and receive permission from the Utility prior to effecting any changes and/or modification of the Customer's wiring or service. Failure to comply with the regulation shall cause the Utility to refuse its service to, or remove its service from, any installation which in the judgment of the Utility will injuriously affect the operation of its system or its service to others.