

PSC NO: 2 ELECTRICITY
COMPANY: MOHAWK MUNICIPAL COMMISSION
INITIAL EFFECTIVE DATE: 6/01/2018

LEAF: 13
REVISION: 4
SUPERSEDING REVISION: 0

SERVICE CLASSIFICATION NO. 3 (CONT'D)

SPECIAL PROVISIONS: (CONT'D)

3. Where an overhead secondary voltage service is greater than 400 amps to non-residential Customers is supplied, the Customer, from the metered point of service entrance, at his or her own expense and in a manner satisfactory to the Utility, shall furnish, install and maintain such switches transformers, regulators, capacitors and other equipment as the Utility may deem necessary to assure stability and compatibility with the system service.
4. Where the underground secondary voltage service is greater than 400 amps to non-residential Customers is supplied, the Customer shall furnish, install and maintain all electrical equipment such as all wire switches, transformer, regulators, capacitors and other required equipment as the Utility may deem necessary to assure stability and compatibility with the system to the point of connection on the Utility's electric system.

Issued by: Andrew Steele and Michael Shedd, Co-Supervisors,
28 Columbia St., Mohawk, NY 13407