Received: 01/31/2019 Status: CANCELLED Effective Date: 01/30/2020

PSC NO: 10 – Electricity Leaf: 79

Consolidated Edison Company of New York, Inc.

Revision: 7

Initial Effective Date: 03/02/2019 Superseding Revision: 6

GENERAL RULES

8. Customer Use of Generating Equipment – Continued

8.3 Generating Facilities Used Under Special Circumstances for Export

The use of generating facilities at the premises for delivery to the Company's primary distribution system will be permitted under special circumstances when the generating equipment is operated at the direction of the NYISO under NYISO SCR procedures or EDRP procedures. Delivery to the Company's secondary networks is prohibited under the above scenarios. The export of electricity discharged by inverter-based Electric Energy Storage systems to the Company's primary or secondary distribution system, or export of electricity discharged by non-inverter based Electric Energy Storage systems to the Company's primary distribution system, will be permitted at the direction of the Company when demand response events are called under the Brooklyn/Queens Demand Management Program or a Non-Wires Alternative project, provided that the Company has determined such export to be safe. A Customer may not deliver to the Company's distribution system while it is receiving electric energy delivered by the Company at the same service point.

A Customer operating its generating equipment pursuant to this General Rule must comply with all Common Provisions of SC 11, including the Interconnection Charge and Determination of Demand, including establishment of a contract demand and installation of appropriate metering to measure the energy delivered to the Company's system. Further, such Customer is required to pay charges as would be required of Customers taking service under SC 11. The Customer will pay any costs associated with reinforcing the distribution system and/or adding facilities as may be required for load delivery.

The Company reserves the right to exclude a generator from connecting to the Company's distribution system when the Company deems it necessary to protect its system, facilities, or other Customers. In addition, the Company may prohibit a Customer from delivering power and energy to the Company's distribution system, or limit the amount of power and energy delivered, for operational reasons.

Issued by: Robert Hoglund, Senior Vice President & Chief Financial Officer, New York, NY

Cancelled by supplement No. 66 effective 01/23/2020 Suspended to 01/30/2020 by order in Case 19-E-0065. See Supplement No. 65. The supplement filing date was 12/18/2019 Suspended to 12/30/2019 by order in Case 19-E-0065. See Supplement No. 62. The supplement filing date was 06/18/2019 Suspended to 06/30/2019 by order in Case 19-E-0065. See Supplement No. 61. The supplement filing date was 02/13/2019