

PSC NO: 10 – Electricity
Consolidated Edison Company of New York, Inc.
Initial Effective Date: 11/06/2015
Issued in compliance with order dated 10/16/2015 in Case 15-E-0407

Leaf: 245
Revision: 4
Superseding Revision: 3

GENERAL RULES

24. Service Classification Riders (Available on Request) – Continued

RIDER R – Net Metering for Customer-Generators – Continued

A. Applicability – Continued

Service will be provided under this Rider to eligible Customers on a first come, first served basis based on the date the Company notifies the Customer that it has received a complete project application in accordance with the SIR. The limit of total rated generating capacity of electric generating equipment served under this Rider (33,246 kW for wind electric generating equipment and 664,920 kW for the total of all other electric generating equipment) is waived to the extent directed by the Commission in its Order issued October 16, 2015, in Case 15-E-0407.

The Company will perform a detailed, site-specific study when it receives a request for interconnection to its distribution network system (distributed and spot networks). Inverter-based solar generators up to 200 kW may interconnect to the Company's distribution network system without such a study if the generating equipment has a rated capacity that does not exceed the peak load delivered to the Customer's premises as measured over the prior 24-month period. The Company reserves the right to decline requests from generators to interconnect to the distribution network system when the Company deems it necessary to protect its system, facilities, or other Customers.

Issued by: Robert Hoglund, Senior Vice President & Chief Financial Officer, New York, NY