

PSC NO: 7 Electricity
City of Jamestown, New York
Effective Date: March 1, 2016

Leaf: 131
Revision: 3
Superseding Revision: 2

SERVICE CLASSIFICATION 1, 2, 3 OR 6 AMENDMENT
PURCHASE OF RENEWABLE ENERGY
FROM NEW DISTRIBUTED GENERATORS

ELIGIBILITY:

Residential or non-residential customers who receive service under Service Classification No. 1, 2, 3 or 6 and own or operate Solar or Wind Electric Generating Equipment with a rated capacity of no more than:

- twenty five kilowatts (25 kW) for Service Classification No. 1
- twenty five kilowatts (25 kW) for Service Classification No. 2 without demand meter
- one hundred kilowatts (100 kW) for Service Classification No. 2 with demand meter
- two hundred kilowatts (200 kW) for Service Classification No. 3 and No. 6

located and used at their premises may be eligible for service under this tariff. Service will be provided to eligible customers under this tariff on a first come, first served basis, until the total rated generating capacity of the individual facilities is equal to 500 kW, or 0.6% of the average system load.

REQUIREMENTS FOR INTERCONNECTION

1. The generating equipment must be designed, installed, interconnected, tested and operated in accordance with applicable government, industry and JBPU requirements and must comply with the New York State Standardized Interconnection Requirements which are available on the Commission website, Distributed Generation Information.

2. All electrical connections must be completed by an Electrical Contractor Licensed in the City of Jamestown and are subject to Inspection by an Electrical Inspector and JBPU staff prior to interconnection. All service connections shall comply with the JBPU Electric Tariff, unless otherwise specified in this Tariff Leaf, or in the Standardized Interconnection Requirements.

3. The JBPU may elect to install a dedicated transformer or transformers if necessary to protect the safety or adequacy of electric service provided to other Customers. Upon written explanation of the decision to require a dedicated transformer, the Customer taking service under this Classification shall pay all costs of installing such transformer.

4. System design output shall not exceed 100% of the prior 12 months of metered energy consumption.

METERING

JBPU will provide one revenue meter for the purpose of billing. This meter will have bidirectional energy flow capability to determine the net amount of energy delivered or received by the JBPU. The charge for this meter will be included in the applicable monthly service charge.

Issued by: David L. Leathers, General Manager
City of Jamestown, New York