

Effective Date: 07/01/2016

PSC NO: 119 ELECTRICITY  
NEW YORK STATE ELECTRIC & GAS CORPORATION  
Initial Effective Date: 07/01/16  
Issued in compliance with Order in Case 15-E-0283, dated June 15, 2016

Leaf: 20.1  
Revision: 0  
Superseding Revision:

### GENERAL INFORMATION

#### 2. How Service May Be Obtained: (Cont'd.)

##### C. Underground Extensions for New Residential Subdivisions: (Cont'd)

###### (9) Exceptions to the General Rule (Cont'd):

- (f) **Connection of Existing Overhead Lines**  
Overhead facilities may be installed when existing overhead distribution lines can be connected by no more than 1,200 feet of extension, if a governmental authority having jurisdiction to do so has not required that underground facilities be installed.
- (g) **One-pole Extension**  
Where a one-pole extension, including but not limited to road crossing pole extensions, would enable an existing overhead distribution line to be connected to a proposed distribution line in a residential subdivision, such extension may be installed overhead, rather than underground; provided, however, that is the necessary facilities are proposed to be in a VSR, the procedures set forth in 16 NYCRR Part 99.2 shall apply.
- (h) **Service Laterals**  
Overhead service laterals may be installed in new subdivisions from existing overhead distribution lines, if a governmental authority having jurisdiction to do so has not required that underground facilities be installed. In unusual circumstances when the application of these rules appears impracticable or unjust to either party or discriminatory to other customers, the applicant or the Company may refer the matter to the Public Service Commission for a special ruling or for approval of special conditions mutually agreed upon prior to commencing construction.

Issued by: James A. Lahtinen, Vice President – Rates & Regulatory Economics, Binghamton, NY