

PSC No. 5 - WATER**COMPANY: NEW YORK AMERICAN WATER COMPANY, INC.****INITIAL EFFECTIVE DATE: MAY 29, 2016****LEAF NO.: 41****REVISION: 0****SUPERSEDING REVISION:****VII. INSTALLATION OF SERVICES (CONTINUED)****F. Specifications**

1. Copper pipe or copper tubing of "K" or P.E.P. wall thickness or equal and approved by the Company shall be laid, but shall not be less than 1" CTS (copper tubing size) in diameter. Where the main has a cover of less than five (5) feet, the service pipe shall have a cover at least equal to that of the main, and in no case shall the service pipe have a cover of less than 4 feet. Where the service pipe must have less than 4 feet of cover in the opinion of the Company, because of ducts or other sub-surface conditions preventing the service being laid at this depth, it shall be sufficiently insulated against frost with a covering of suitable waterproof material. The installation shall be subject to the Company's inspection at the Company's expense.
2. Where an applicant is seeking service at an elevation or gradient which could not otherwise be adequately serviced by existing plant, the Company will require that the applicant bear the additional cost of providing such extraordinary service, or in the alternative, require the applicant to purchase, install and maintain the necessary, special equipment, such as a hydro-pneumatic system, needed to serve the premises. The installation of a hydro-pneumatic system as part of the customer's internal plumbing may be subject to approval of the Health Department, and should comply with local building codes and standards.

G. Metering Equipment

1. Meters
 - 1.1. An individual meter shall be required for each premises and for each separate service connection to a premises.
 - 1.2. The meter will be furnished and connected by the Company without cost to the customer. The Company reserves the right in all cases to stipulate the size, type and make of the meter to be used on any connection.
 - 1.3. All meters and meter connections shall at all times remain the sole property of the Company, and shall not be interfered with in any respect. All meters will be maintained by and at the expense of the Company so far as ordinary wear and tear are concerned but the customer will be held responsible for damages due to freezing, hot water or other external causes. In case of damage the Company will repair the meter, if necessary replacing it with another meter and the costs shall be paid by the customer. The Company recommends the customer install, at the customer's expense, suitable equipment properly located to prevent backflow of hot water which may cause damage to the meter, or other damage to the customer's plumbing.
 - 1.4. The Rules and Regulations of the Public Service Commission require that the Company shall periodically test all meters in service. For this reason, it is incumbent on all customers to permit the Company to remove meters periodically for test and repair. The Company also reserves the right to remove and test any meter at any time, upon reasonable notice, and to substitute another meter in its place. Non-residential customers are referred to Section VI subsection K providing for discontinuance of service in the event of refusal. Residential customers are referred to Section VI subsection F, "No Access Procedures".

Issued by: Brian K. Bruce, President, 60 Brooklyn Avenue, Merrick, New York 11566