

PSC No: 120 - Electricity
New York State Electric and Gas Corporation
Initial Effective Date: April 29, 2016
Issued in compliance with Order in Case 15-E-0557, dated March 18, 2016
GENERAL INFORMATION

Leaf No. 117.35
Revision: 7
Superseding Revision: 6

29. Micro-combined Heat and Power (MCHP) Service Option

Applicable to any Residential Customer (as defined by HEFPA) who owns, leases or operates MCHP generating equipment. MCHP generating equipment is defined as an integrated, cogenerating building heating and electrical power generation system, operating on any fuel and of any applicable engine, fuel cell, or other technology, with a rated capacity of at least one kW and not more than 10 kW electric and any thermal output that at full load has a design total fuel use efficiency in the production of heat and electricity of not less than 80%, and annually produces at least 2,000 kWh of useful energy in the form of electricity that may work in combination with supplemental or parallel conventional heating systems, that is manufactured, installed and operated in accordance with applicable government and industry standards, that is connected to the electric system and operated in conjunction with an electric company's transmission and distribution facilities. Such system must be connected to the customer's electric system and operated in parallel with the Company's transmission and distribution facilities.

Application of the MCHP Residential Service Option shall be available to eligible customers, on a first come, first served basis, until the total rated generating capacity for solar, farm waste, MCHP and fuel cell electric generating equipment owned, leased or operated by customer-generators in the Company's service area is equivalent to 169,560 kW (6% of the Company's electric demand for the year 2005) and is available only in non-network areas of the Company's territory. However, the maximum amount of net metered generation that the Company must interconnect shall float for an interim basis until such time as the interim period ends as directed by the Commission in its Order issued October 16, 2015 in Case 15-E-0407.

Customers electing service under this provision must execute a New York State Standardized Contract for Interconnection of New Distributed Generation Units with Capacity of 5 MW or Less Connected in Parallel with Utility Distribution Systems ("SIR Contract"). In addition, customers must operate in compliance with standards and requirements set forth in the New York State Standard Interconnection Requirements and Application Process for New Distributed Generators 5 MW or Less Connected in Parallel with Utility Distribution Systems, as set forth within Addendum-SIR of P.S.C. No. 119.

For a net metered customer, the Company shall install metering appropriate for the customer's service classification that enables the Company to measure the electricity delivered to the customer and measure the electricity supplied by the customer to the Company. Where the Company determines that a second meter should be installed, no additional costs shall be billed to the customer. When a second meter is requested by the customer that is not required by the Company, the customer shall be responsible for the cost of the meter, the installation and any additional costs. For each billing period during the term of the SIR Contract, the Company shall net the electricity (kWh) delivered to the customers with the electricity (kWh) supplied by the customer to the Company.

- a) If the electricity (kWh) supplied by the Company exceeds the electricity supplied by the customer to the Company during the billing period the customer shall be billed for the net kWh supplied by the Company to the customer at the standard service class rates. For customers billed on time-differentiated rates (TOU meter), e.g., On-Peak/Off-Peak or Day/Night, netting shall occur in each time period.
- b) If the electricity (kWh) supplied by the customer to the Company during the billing period exceeds the electricity (kWh) supplied by the Company to the customer, the Company shall provide a credit on the next bill for net electricity supplied at the Company's avoided cost Service Classification 10 energy rate. For customers billed on time-differentiated rates (TOU meter), e.g., On-Peak/Off-Peak or Day/Night, the kWh credit shall be a credit for the appropriate time period.

ISSUED BY: James A. Lahtinen, Vice President Rates and Regulatory Economics, Binghamton, New York