

PSC NO: 1 ELECTRICITY  
COMPANY: VILLAGE OF WESTFIELD  
INITIAL EFFECTIVE DATE: 6/22/16

LEAF: 17  
REVISION: 0  
SUPERSEDING REVISION:

#### SERVICE CLASSIFICATION NO.7 (cont.)

3. if applicable, a description of where the proposed system is not in compliance with these requirements;
4. a good faith, detailed estimate of the total cost of completion of the interconnection of the proposed system and/or a statement of cost responsibility for required interconnection equipment.

#### APPLICANT COMMITS TO UTILITY CONSTRUCTION OF UTILITY'S SYSTEM MODIFICATIONS

The applicant and utility will execute "Form A", a standardized contract for interconnection and the applicant will provide the utility with an advance payment for the utility's estimated costs as identified in good faith estimate provided by Village of Westfield as part of the completion of the CESIR (estimated costs will be reconciled with actual costs as part of final acceptance).

#### PROJECT CONSTRUCTION

The applicant will build the facility in accordance with the utility-accepted design. The utility will commence construction/installation of system modifications and metering requirements as identified in completion of CESIR. Utility system modifications will vary in construction time depending on the extent of work and equipment required. The schedule for this work is to be discussed and agreed upon with the applicant.

#### TEST FACILITY IN ACCORDANCE WITH STANDARDIZED INTERCONNECTION REQUIREMENTS

The verification testing will be performed in accordance with the written test procedure provided in the detailed interconnection design package and any site-specific requirements identified by the utility. Final testing will be conducted within ten (10) business days of complete installation at a mutually agreeable time and shall be witnessed by the Village of Westfield.

#### INTERCONNECTION

The applicant's facility will be allowed to commence parallel operation upon satisfactory completion of the facility's tests. In addition, the applicant must have complied with and must continue to comply with all contractual and technical requirements.

Issued by: Andrew Thompson Director of Public Works, 23 Elm Street, Westfield, NY 14787