

PSC No: 120 - Electricity
New York State Electric & Gas Corporation
Initial Effective Date: April 1, 2017
Issued in compliance with Order in Case Nos. 15-E-0751 an 15-E-0082, dated March 9, 2017.

Leaf No. 117.46.21.1
Revision: 0
Superseding Revision:

GENERAL INFORMATION

37. Community Distributed Generation (Cont'd)

6. Metering Requirement

- a. For a CDG Host with a Net Metered Generation Facility that has completed Step 8 of the SIR Addendum-SIR or has installed Net Metered Generation Facility on or prior to March 9, 2017 ("Existing"), the Company shall install metering appropriate for the customer's service classification that enables the Company to measure the electricity delivered to the customer and measure the electricity supplied by the customer to the Company. Where the Company determines that a second meter should be installed, no additional costs shall be billed to the customer. When a second meter is requested by the customer that is not required by the Company, the customer shall be responsible for the cost of the meter, the installation, and any additional costs.
- b. For a CDG Host with a Net Metered Generation Facility that does not meet the requirements in 6.a., the Company shall install metering capable of recording net hourly consumption and injection for a customer. The customer shall be responsible for the cost of the meter, the installation, and any additional costs.

ISSUED BY: Joseph J. Syta, Vice President, Controller and Treasurer, Binghamton, New York