

PSC NO: 87 GAS

LEAF: 27

COMPANY: NEW YORK STATE ELECTRIC & GAS CORPORATION

REVISION: 4

INITIAL EFFECTIVE DATE: January 14, 2017

SUPERSEDING REVISION: 3

Issued in compliance with Order in Case No. 15-G-0185, dated December 16, 2016.

SERVICE CLASSIFICATION NO. 3 (CONT'D)**INTERRUPTIBLE SALES SERVICE (CONT'D)****SPECIAL PROVISIONS - ALL CUSTOMERS: (CONT'D)**

- C. Customers taking service under this service classification may be required to install daily metering equipment, at the sole discretion of the Company.
- D. The Customer shall provide the Company with an affidavit certifying the grade and sulphur content of fuel oil that can be utilized in the facilities served under this service classification or a description of the alternate fuel used.
- E. The Company may, at its sole discretion, adjust the prices charged customers that are exempt from the Petroleum Business Tax (PBT), imposed by Article 13-A of the New York State Tax Law. Such adjustments shall be made on a non-discriminatory basis, such that, PBT-exempt customers within the same price area and price category receive the same PBT adjustment.
- F. Customers taking service under this service classification must negotiate an individual Service Agreement with the Company.
- G. Effective January 14, 2017, the Company shall implement daily communication with each interruptible customer facility location via email, text messages, fax or phone call, as soon as weather forecasts project average daily outside temperatures to be 20 degrees or below for the upcoming three consecutive days or during times when three days of consecutive customer interruptions occur. Additionally, the Company shall contact each interruptible customer facility location at the end of every interruption to remind customers to replenish alternate fuel inventories as needed to maintain minimum levels.

SPECIAL PROVISIONS - DISTILLATE FUEL CUSTOMERS:

- A. A Distillate Fuel Customer is a Customer that uses No. 2 fuel oil, diesel or kerosene.
- B. On November 1 of each year, a Distillate Fuel Customer meeting the alternate fuel requirement, as set forth in this service classification, is required to have an adequate supply of distillate fuel on-hand. A distillate fuel supply shall be considered on-hand and adequate if the supply is either: (a) on-site and sufficient to meet a minimum of 10 consecutive days requirements; or (b) if Customers physical facilities are insufficient to provide for a 10-day supply, then the Customer must: (i) have a full distillate fuel tank(s); and (ii) provide verification, to the Company's satisfaction, of alternative fuel supplies, other than spot market purchase of distillate fuel that, in combination with (a), provides for a 10-day supply.

Issued By: James A. Lahtinen, Vice President – Rates & Regulatory Economics, Binghamton, NY