

P.S.C. No. 1 – Water
SUEZ Water New York Inc.
Initial Effective Date: February 1, 2017

Leaf No. 21
Revision: 0
Superseding Revision:

GENERAL INFORMATION

3.5 Pipes on Customer's Premises

The entire pipe shall be copper tubing or other pipe of strength and quality approved in advance by the Company. The minimum diameter of the pipe shall be 3/4-inch. For services two inches or larger in diameter, ductile iron or other pipe of strength and quality approved by the Company shall be used.

3.6 Minimum Depth of Service Pipes

Minimum depth of service pipes from mains to premises shall be four feet six inches below the finished surface of the ground. Where covering over mains is less than five feet, the connection shall be made on the side of the main, and the service pipe shall in no case have less covering than the main.

3.7 Connecting Pipe

A. That portion of the pipe without the territorial limits of any street, avenue, road or way, as hereinbefore defined, which is installed by the Customer at his expense, shall be subject to the approval of the Company before the trench is backfilled.

B. No attachment to such pipe or any branch thereof shall be made between the meter and the main.

C. The Company may refuse to permit an Applicant to connect to its service pipe, unless the connecting pipe and other plumbing are in accordance with the plumbing and sanitary rules of the municipality and the Rules and Regulations of the Company.

4. METERED SERVICE

4.1 Meters Furnished by Company

A. The Company will furnish, install, and maintain meters, and will determine the size, type and make of meter to be used.

The Customer shall furnish, install and maintain on his premises the necessary piping, fittings, valves, pressure reducing valve, backflow preventer devices, pipe coupling, meter couplings or meter flanges to receive the meter.

B. All meters installed by the Company shall be set at "zero" or shall contain a tag indicating the meter reading at the time of installation.

Issued in compliance with the Commission Order 16-W-0130 dated January 24, 2017

Issued by: Christopher J. Graziano, V.P. & Gen Mgr., 360 West Nyack Road, West Nyack, NY 10994