

PSC NO: 15 ELECTRICITY

LEAF: 272.1

COMPANY: CENTRAL HUDSON GAS & ELECTRIC CORPORATION

REVISION: 4

INITIAL EFFECTIVE DATE: 12/1/2016

SUPERSEDING REVISION: 3

Issued in Compliance with Order in Case 16-E-0497 dated November 17, 2016

SERVICE CLASSIFICATION NO. 14 (Cont'd)STANDBY SERVICE (Cont'd)STANDBY SERVICE IS NOT APPLICABLE TO: (Cont'd)

Standby service rates shall not apply to the following customers, provided they comply with the Standardized Interconnection Requirements set forth in the SIR-Addendum of this Rate Schedule:

- 1) residential retail customers with photovoltaic generating systems 25 kilowatts or less
- 2) residential retail customers with wind electric generating equipment with a rated capacity of 25 kilowatts or less for residential wind generation or 500 kilowatts or less for farm service wind generation where the customer's primary residence is located on the same land used for such farm service
- 3) retail customers with farm waste electric generating systems 2,000 kilowatts or less
- 4) non-residential retail customers with photovoltaic generating systems 2,000 kilowatts or less
- 5) non-residential retail customers with wind electric generating equipment with a rated capacity of 2,000 kilowatts or less

Emergency Generators

Standby service shall not apply to customers whose only generating units are emergency generators. For the purposes of this Service Classification, a generating unit must be designated in the customer's Application for Electric Standby Service with the Company as an emergency generator and must meet each of the following requirements to be considered an emergency generator:

- 1) the emergency generator is not capable of being operated in parallel with the Company's delivery system, except for closed-transition transfer switching where the term "closed-transition transfer" is characterized as a momentary make-before-break switching sequence, and
- 2) the emergency generator is used exclusively for purposes of supplying electrical power to the customer when electrical power is not available from the Company, and
- 3) no load is served by the emergency generator while electric service is available from the Company to the premises, except for regularly scheduled tests when the generator is required to operate under load or for NYISO Emergency Response Programs or for NYISO unforced capacity requirements for special case resources, and

Issued by: Anthony S. Campagiorni, Vice President, Poughkeepsie, New York