

PSC NO: 10 – Electricity
Consolidated Edison Company of New York, Inc.
Initial Effective Date: 02/01/2014

Leaf: 244
Revision: 3
Superseding Revision: 2

GENERAL RULES

24. Service Classification Riders (Available on Request) – Continued

RIDER R - Net Metering for Customer-Generators

Applicable to SCs 1, 2, 5, 8, 9, 12, and 13

A. Applicability

1. To any residential Customer with solar electric generating equipment located and used at the Customer's residence, provided the equipment has a rated capacity of not more than 25 kW unless the residence is also the location of the Customer's Farm Operation, in which case the equipment may have a rated capacity of not more than 100 kW;
2. To any Customer with farm waste electric generating equipment (as defined in Public Service Law Section 66-j) with a rated capacity of not more than 1,000 kW, provided such equipment is located and used at the Customer's Farm Operation;
3. To any non-residential Customer with solar electric generating equipment or wind electric generating equipment with a rated capacity of not more than 2,000 kW located and used at its premises;
4. To any residential Customer with wind electric generating equipment located and used at his or her primary residence, provided the equipment has a total rated capacity of not more than 25 kilowatts unless the primary residence is also the location of the Customer's Farm Operation, in which case the equipment may have a total rated capacity of not more than 500 kW, as specified in Public Service Law Section 66-l;
5. To any residential Customer with micro-combined heat and power ("micro-CHP") generating equipment (as defined in Public Service Law Section 66-j) located and used at the Customer's premises, provided such equipment has a rated capacity of at least 1 kW and not more than 10 kW and meets the requirements specified in Public Service Law Section 66-j and in the Standardized Interconnection Requirements;
6. To any Customer with fuel cell electric generating equipment (as defined in Public Service Law Section 66-j) located and used at the Customer's premises, provided (a) in the case of a residential Customer, such equipment has a rated capacity of not more than 10 kW, or (b) in the case of a non-residential Customer, such equipment has a rated capacity of not more than 1,500 kW; and
7. To any Customer with micro-hydroelectric ("micro-hydro") generating equipment located and used at the Customer's premises, provided (a) in the case of a residential Customer, such equipment has a rated capacity of not more than 25 kW, or (b) in the case of a non-residential Customer, such equipment has a rated capacity of not more than 2,000 kW.

Issued by: Robert Hoglund, Senior Vice President & Chief Financial Officer, New York, NY