

P.S.C. NO. 3 ELECTRICITY

LEAF: 188

ORANGE AND ROCKLAND UTILITIES, INC.

REVISION: 2

INITIAL EFFECTIVE DATE: April 1, 2013

SUPERSEDING REVISION: 1

Issued in compliance with Order in Case 12-E-0398 dated 3/15/2013.

GENERAL INFORMATION**13. SERVICE CLASSIFICATION RIDERS (Continued)****RIDER N (Continued)****NET METERING FOR CUSTOMER GENERATORS****INTERCONNECTION AND OTHER TECHNICAL REQUIREMENTS (Continued)**

- (G) The customer is solely responsible for providing adequate protection for customer's facilities operating in parallel with the Company's system. Except where caused by the Company's negligence, the Company will not be liable for, and the customer shall indemnify and hold the Company harmless for damages to the property of the Company or others or injuries to persons arising out of any occurrence related to the customer's ownership, use or operation of the customer's facilities.
- (H) Voltage Regulation and Power Factor Correction - The customer is responsible for voltage regulation beyond the point of common coupling. The customer is strongly advised not to add power factor correction capacitors to a facility where it is possible to operate isolated from the utility.
- (I) Additional Generation - Generation that does not qualify for net metering may not be interconnected with the utility on the same service.

Issued By: John McAvoy, President, Pearl River, New York