

PSC NO: 12 GAS

LEAF: 382

COMPANY: THE BROOKLYN UNION GAS COMPANY

REVISION: 6

INITIAL EFFECTIVE DATE: 11/01/14

SUPERSEDING REVISION: 5

STAMPS:

SERVICE CLASSIFICATION No. 18 – Continued**J. SPECIAL PROVISIONS FOR NCTS 18-6C, 18-6G AND 18-6M (continued)****2. Company Responsibility:**

- a. The Company reserves the right to accept only such applications under this Service Classification as will, in the Company's sole judgment, permit it to dispose of the gas it has available for sale without requiring an unreasonable or uneconomic extension of facilities.
- b. Control devices, whether automatic or semi-automatic, will be set at the Designated Temperatures. The Company will notify Customers of the current Designated Temperatures prior to the start of each winter.
- c. The Company will be responsible for the maintenance of Company-owned equipment. This equipment is identified as the meter, the remote switchover and meter reading equipment, and all associated wiring and relays associated with that equipment.

3. Customer Responsibility:

- a. It is understood and agreed that as a condition of service hereunder Customers are required to transfer their fuel supply from gas to an alternate fuel source when the Local Outside Temperature reaches the Designated Interruption Temperature or there is a Company-initiated interruption, whichever occurs first.
- b. Unless otherwise expressly authorized by the Company in writing, a supply of alternate fuel sufficient to meet the Customer's fuel consumption needs for a period of ten (10) days is the minimum required standby alternate fuel supply at the beginning of the heating season.
- c. Customer will at all times maintain dual-fuel equipment and a sufficient standby alternate fuel supply throughout the heating season in the event that transfer off of natural gas is required pursuant to this Service Classification.
- d. Such dual-fuel equipment and all associated control devices, the installation and the subsequent operation thereof will be subject to the Company's inspection and requirements.

Issued by: Kenneth D. Daly, President, Brooklyn, New York