

**P.S.C. NO. 3 ELECTRICITY**  
**ORANGE AND ROCKLAND UTILITIES, INC.**  
 INITIAL EFFECTIVE DATE: July 27, 2015

LEAF: 180  
 REVISION: 5  
 SUPERSEDING REVISION: 4

## GENERAL INFORMATION

### 13. SERVICE CLASSIFICATION RIDERS (Continued)

#### RIDER N (Continued)

#### NET METERING FOR CUSTOMER GENERATORS

##### APPLICABILITY (Continued)

- (G) For a residential customer, micro-combined heat and power ("Micro-CHP") generating equipment with a rated capacity of at least 1 kW and not more than 10 kW. Prior to commencing service under this Rider, a customer with Micro-CHP generating equipment must submit technical documentation, acceptable to the Company, establishing that the equipment meets the requirements specified in Public Service Law Section 66-j and in the SIR. No more than once annually thereafter, the Company may require the customer to submit technical documentation in order to establish continued eligibility. A customer who fails to provide documentation acceptable to the Company within 30 days of a Company request will be deemed ineligible to take service under this Rider until the first billing cycle commencing after acceptable documentation is provided.
- (H) For a residential customer, fuel cell generating equipment with a rated capacity of not more than 10 kW.
- (I) For a residential customer (other than a farm utilizing a residential meter), qualifying solar electric generating equipment with rated capacity of not more than 25 kW, unless the residence is also the location of the customer's farm operation as defined in Subdivision 11 of Section 301 of the Agricultural and Markets Law, in which case the equipment may have a rated capacity of not more than 100 kW.

The kW of facilities with generating equipment located near each other will be aggregated to determine if the kW limit is met unless each facility meets all of the following criteria: (a) each is located on a separate site (i.e., a separately deeded location); (b) each is separately metered and interconnected to the Company's grid; and (c) each is operated independently of the others. The aggregated rated capacity of electric generating equipment shall be limited to 25 kW for residential customers and 2 MW for non-residential customers. The Company will waive the 2 MW limit for a customer whose solar electric generating facility successfully participated in the NYSERDA – Competitive Solar PV Solicitation: Program Opportunity Notice ("PON") 2589, PON 2860, or PON 2956 if the customer demonstrates that the PON participant made good faith efforts to comply with the 2 MW limit in configuring its proposal.

Customers with generators that exceed the rated capacity thresholds in (A) - (I) above are required to take service under Service Classification No. 25 of this Rate Schedule.

Issued By: Timothy Cawley, President, Pearl River, New York