October 4, 2007

VIA ELECTRONIC FILING

Honorable Jaclyn A. Brilling, Secretary New York State Public Service Commission Three Empire State Plaza Albany, NY 12223-1350

Re: New York State Electric & Gas Corporation Street Lighting and Outdoor Lighting Tariff Revisions

Dear Secretary Brilling:

The enclosed tariff leaves, issued by New York State Electric & Gas Corporation ("NYSEG" or "the Company") are transmitted for filing in compliance with the requirements of the New York State Public Service Commission ("PSC" or "Commission") and Appendix 7-H (electronic tariff filing system) to the Commission's Codes, Rules and Regulations (16 NYCRR Appendix 7-H). The leaves are proposed to become effective on January 1, 2008.

P.S.C. No. 120 – Schedule for Electric Service

Leaf No. 184, Revision 6 Leaf No. 188, Revision 7 Leaf No. 194, Revision 6 Leaf No. 196, Revision 2 Leaf No. 198, Revision 14 Leaf No. 198.2, Revision 2 Leaf No. 201, Revision 14 Leaf No. 201, Revision 5 Leaf No. 202, Revision 6

P.S.C. No. 121 – Schedule for Electric Service Street Lighting Leaf No. 4, Revision 2 Leaf No. 26, Revision 6 Leaf No. 28, Revision 7 Leaf No. 31, Revision 9 Leaf No. 34.3, Revision 7 Leaf No. 35, Revision 7 Leaf No. 39, Revision 2 Leaf No. 41, Revision 6 Leaf No. 42, Revision 6 Leaf No. 43, Revision 6 Leaf No. 46, Revision 7

Leaf No. 47, Revision 7

Jaclyn A. Brilling, Secretary Page 2 of 3 October 4, 2007

> Leaf No. 55, Revision 7 Leaf No. 56, Revision 6 Leaf No. 57, Revision 6

Purpose of the Filing

The Company is filing revisions to its tariffs, as described below, to comply with the requirements of the Energy Policy Act (EPAct) signed into law on August 8, 2005 and to provide a new option to customers as Mercury Vapor fixtures are replaced. The Company is also proposing to grandfather obsolete and energy inefficient fixtures.

Details of Tariff Revisions

Section 135, Energy Conservation Standards For Additional Products, sub-section (ee) of EPAct specifically states, "Mercury vapor lamp ballasts shall not be manufactured or imported after January 1, 2008."

Revisions to NYSEG's Outdoor Lighting and Street Lighting tariffs are necessary to comply with this Federal requirement and make known to customers that Mercury Vapor fixtures will no longer be available for new service hook-ups nor to replace failed existing Mercury Vapor fixtures. The Company will use a plus sign (+) in its tariff to symbolize that existing Mercury Vapor installations will not be replaced in kind upon failure within its tariff.

NYSEG has received requests from its customers to expand its tariff to include Metal Halide fixtures as a replacement option for Mercury Vapor fixtures because customers do not want the amber hue emitted by High Pressure Sodium fixtures. Therefore, the Company is proposing to offer additional Metal Halide fixtures within its Street Lighting tariff. The Company is also proposing to offer a Metal Halide Power Bracket in its Outdoor Lighting tariff.

In addition, the Company is proposing tariff revisions to indicate that Incandescent and Fluorescent light fixtures will not be replaced in kind. These types of fixtures are outdated and inefficient. When existing Incandescent and Fluorescent installations fail, customers will be able to select from the other types of fixtures available in NYSEG's tariff.

Publication

In accordance with the requirement of Section 66 (12)(b) of the Public Service Law and 16 NYCRR Section 720-8.1 as to newspaper publication, notice of the proposed tariff changes will be published once in each week for four successive weeks in newspapers having general circulation in each customer rate area affected by the proposed changes. Jaclyn A. Brilling, Secretary Page 3 of 3 October 4, 2007

A State Administrative Procedures Act Notice is enclosed for publication in the State Bulletin.

Company Contacts

Please direct any questions pertaining to this filing to Lori Cole at (607) 762-8710 or to me at (607) 762-7341.

Very truly yours,

Christine M. Stratakos Manager, Pricing & Analysis Rates & Regulatory Economics

Enclosures